


PE L1 L2 L3 N



Vello Elektro BV
 Typograaf 14
 6921 VB Duiven NL
 +31(0)316 251500

V40.2.0043-S

A4

I _{nA}	125A	Date	18.07.2018	Name	EP	Remarks	
U _{nA}	400V	Design					Page 1
f _n (AC)	50hZ	Check					Of 1
RDF	0,8	Adjustment					
Internal wiring H07V-K unless otherwise noted				According to NEN-EN-IEC-61439			