



Vello Elektro BV  
 Typograaf 14  
 6921 VB Duiven NL  
 +31(0)316 251500

V40.2.0125-S

A4

$I_{nA}$	400A		Date	Name	Remarks	Page
$U_{nA}$	400V	Design	25.04.2019	EP		1
$f_n$ (AC)	50hZ	Check				Of 1
RDF	0,6	Adjustment				
Internal wiring H07V-K unless otherwise noted			According to NEN-EN-IEC-61439			